

Gladeville / Cranberry Sewer: The field crews have located/inspected the majority of the manholes so far. There are a few areas where all of them weren't located and we'll need to go back and try to find. Most of the manholes were found to be in generally good condition, but there were a handful of locations where significant inflow sources were found. Smoke testing of the system is just about completed.