

Fire Hydrant #	Physical Address	Comments	Parts Ordered
884-5		valve ok	
FH 270	Exit 19 South	ok	
FH 224	5866 Coulson Church Road	Broken 2 1/2 nozzle	yes
FH 222	6195 Coulson Church Road	ok	
FH 221	6319 Coulson Church Road	ok	
FH 220	6571 Coulson Church Road	tag out - broke	yes
FH 219	6733 Coulson Church Road	Full of water	yes
FH 216	6955 Coulson Church Road	ok	
FH 215	7136 Coulson Church Road	ok	
FH 214	7339 Coulson Church Road	ok	
FH 213	7561 Coulson Church Road	ok	
FH 210	7743 Coulson Church Road	ok	
FH 206	7945 Coulson Church Road	ok	
FH 205	8133 Coulson Church Road	ok	
FH 204	198 Pine Grove Road	ok	
FH 207	76 Sunrise Drive	?	
FH 208	323 Sunrise Drive	needs straightened up	made work order
FH 209	460 Sunrise Drive	ok	
FH 211	194 Rotenizer Drive	ok	
FH 267	4958 Coulson Church Road	ok	
FH 262	4747 Coulson Church Road	no note	
FH 263	4553 Coulson Church Road	ok	
FH 264	4369 Coulson Church Road	ok	
FH 265	4127 Coulson Church of Brethren	ok	
FH 266	48 Monorat Road	ok	
FH 261	149 Oak Grove Road	ok	
FH 259	631 Oak Grove Road	ok	
FH 258	879 Oak Grove Road	ok	
FH 257	1019 Oak Grove Road	ok	
FH 256	1270 Oak Grove Road	ok	
FH 255	1429 Oak Grove Road	ok	
FH 685	1865 Oak Grove Road	ok	
FH 682	1945 Wagon Wheel	ok	
FH 681	356 Wagon Wheel	ok	
FH 686	2205 Oak Grove	ok	
FH 687	253 Knob Hill	ok	
FH 683	2359 Oak Grove	ok	
FH 670	186 Monorat	ok	
FH 689	2097 Monorat	ok	
FH 688	Intersection Monorat	ok	
FH 253	100 Pickett	ok	
FH 251	Laurel Rescue Squad	ok	
FH 252	1360 Rescue Road	ok	
FH 250	Laurel School	ok	
FH 217	132 Rescue Road	ok	
FH 218	308 Rescue Road	ok	
FH 247	469 Resuce Road	ok	
FH 246	714 Rescue Road	ok	
FH 271	4230 Airport Road	ok	
FH 245	927 Airport Road	ok	
FH 244	1155 Pleasant View	ok	
FH 243	1349 Pleasant View	ok	
FH 242	1569 Pleasant View	ok	
FH 240	2031 Pleasant View	ok	
FH 239	2202 Pleasant View	ok	
FH 238	Before Pleasant View Tank	?	
FH 237	286 Pleasant View	ok	

FH 236	2965 Pleasant View	Hyd Leaking	yes
FH 235	3116 Pleasant View	ok	
FH 234	3515 Pleasant View	ok	
FH 233	At Rt 743 Poplar camp road	ok	
FH 232	At Master Meter Pit Poplar Camp Road	ok	
FH 358	412 Coulson Church Road	ok	
FH 361	607 Coulson Church Road	ok	
FH 362	449 HoneyCutt Dam Road	ok	
FH 363	831 Honeycutt dam Road	ok	
FH 364	319 Hawk Landing Drive	ok	
FH 365	60 Spring Hollow Lane	ok	
FH 366	35 Falcon Lane	ok	
FH 368	198 Falcon Drive	ok	
FH 367	1242 Honeycutt Dam Road	ok	
FH 359	237 Rabbits Run	ok	
FH 360	556 Couison Church Road	ok	

Inspection Checklist

Date: _____

Inspector: _____

Is the hydrant shutoff valve visible?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Is the hydrant shutoff valve operational?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Is the hydrant shutoff valve in the open position?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Is the hydrant painted the appropriate color(s)?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Is the paint in good condition?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Is there 3 feet clearance around the hydrant?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Is the ground level below the safety flange?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Are all caps present?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Are all caps easily removed? <i>(and greased)</i>	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Do the cap chains swing freely? <i>(and attached)</i>	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Is the operating stem nut in good condition?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Does the operating stem operate properly?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Does the hydrant provide the expected flow?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No
Does the hydrant drain when turned off?	<input type="checkbox"/>	Yes	<input type="checkbox"/>	No

Recorded Pressures & Flows

Inspector: _____

Date		Diameter	2-1/2-inches
Static	psi	Residual	psi
Pitot	psi	Residual Flow	gpm

Comments: *(Any "No's" on the checklist should be described)*
