

EXIT 1 UPDATE

MARCH

Installed new Equalization basin blower
Installed 2 new Equalization flow pumps
Installed 2 new Equalization check valves
Placed more gravel inside the sewer plant
New gravel in the parking lot
New gravel at the wet well
Hauled off old pumps
Cleaned office area and meters
Pulled pumps at wet well unclogged 1 and replaced 1
Cleaned and removed grass around outfall pipe
AEP set pole for 3 phase power
DEQ visited plant on Feb. 8th
Replaced lighting in plant